



Evaluation of EPA's Test for Pressure Regulating Sprinklers

Irrigation Show & Education Conference Nov. 6-10, 2017

Bernardo Cardenas

Agricultural & Biological Engineering University of Florida/IFAS

abe.ifas.ufl.edu

Background

ASABE/ICC Sprinkler & Emitter Standard




Committee Composition

- Irrigation manufacturers
- Utilities
- Irrigation Association
- Irrigation contractors
- Researchers

ASABE/ICC 802-2014

Landscape Irrigation Sprinkler and Emitter Standard

American National Standard




Background

- ASABE/ICC Sprinkler & Emitter Standard
- Potential savings → flowrate reduction at elevated operating pressures



Theoretical Pressure Regulation Flowrate Reduction



FLORIDA

Pressure and Flowrate

12' SERIES WITH 24° TRAJECTORY (BROWN)

Arc	Dese	nci		Ra-	Prec. Rate		
	Desc.	psi	gpm	dius			
90°		20	0.40	11	1.48	1.28	
	12.0	30	0.50	12	1.55	1.35	
	12-Q	40	0.60	13	1.64	1.42	
		50	0.63	13	1.67	1.44	
	12-Q-PC	30-40	0.48	12	1.49	1.29	
	12-4-PC	40-75	0.53	12	1.65	1.43	
	12-T 12-T-PC	20	0.57	11	1.58	1.37	
120°		30	0.72	12	1.68	1.45	
		40	0.87	13	1.87	1.62	
		50	0.97	13	1.93	1.67	
		30-40	0.64	12	1.49	1.29	
		40-75	0.70	12	1.63	1.41	
		20	0.95	11	1.76	1.52	
1009	12.11	30	1.09	12	1.69	1.47	
180°	12-H	40	1.30	13	1.72	1.49	
		50	1.55	14	1.77	1.53	
	12-H-PC	30-40	0.96	12	1.49	1.29	
	12-11-PC	40-75	1.05	12	1.63	1.41	

Center for

UF FLORIDA

IFAS

40-75 1.05	12 1.63 1.4									40		15	1.04	1.77	2.04	
		- 1								20		11	1.05	1.67	1.93	
	12 Series MPR						18	0°	н	25		12	1.18	1.58	1.83	
	30° Trajectory				_					30		12	1.30	1.74	2.01	
										35		13	1.42	1.61	1.86	
	Nozzle	Pressure	Radius	Flow	Precip	Precip				40		13	1.52	1.73	2.00	
		psi	ft.	gpm	In/h	In/h										
	12F	15	9	1.80	2.14	2.47										
		20	10	2.10	2.02	2.34										
		25	11	2.40	1.91	2.21										
		30	12	2.60	1.74	2.01										
	12H	15	9	0.90	2.14	2.47										
		20	10	1.05	2.02	2.34								a v		100
		25	11	1.20	1.91	2.21		1	/				11	. /		
		30	12	1.30	1.74	2.01										
	lal			M			12				12				M	

12 12' radius Fixed: ¼, ½, ½, ⅔, ¾, Full Green Trajectory: 28°

Arc	Position	Pressure PSI	Radius ft.	Flow GPM	Precip	o in∕hr ▲
		20	11	0.54	1.71	1.98
90°	Q	25	12	0.61	1.62	1.87
	-	30	12	0.67	1.78	2.06
_		35	13	0.72	1.65	1.90
		40	13	0.78	1.77	2.04
		20	11	0.72	1.71	1.98
120°	Т	25	12	0.81	1.62	1.87
		30	12	0.89	1.78	2.06
		35	13	0.97	1.65	1.90
		40	13	1.04	1.77	2.04
		20	11	1.05	1.67	1.93
180°	н	25	12	1.18	1.58	1.83
		30	12	1.30	1.74	2.01
		35	13	1.42	1.61	1.86
		40	13	1.52	1.73	2.00

Pressure and Flowrate

12' SERIES WITH 24° TRAJECTORY (BROWN)

Arc	Dese	nci		Ra-	Prec. Rate		
	Desc.	psi	gpm	dius			
90°		20	0.40	11	1.48	1.28	
	12.0	30	0.50	12	1.55	1.35	
	12-Q	40	0.60	13	1.64	1.42	
		50	0.63	13	1.67	1.44	
	12 0 00	30-40	0.48	12	1.49	1.29	
	12-Q-PC	40-75	0.53	12	1.65	1.43	
	12-T 12-T-PC	20	0.57	11	1.58	1.37	
120°		30	0.72	12	1.68	1.45	
-		40	0.87	13	1.87	1.62	
		50	0.97	13	1.93	1.67	
-		30-40	0.64	12	1.49	1.29	
		40-75	0.70	12	1.63	1.41	
		20	0.95	11	1.76	1.52	
1009	12.11	30	1.09	12	1.69	1.47	
180°	12-H	40	1.30	13	1.72	1.49	
		50	1.55	14	1.77	1.53	
_	12-H-PC	30-40	0.96	12	1.49	1.29	
	12-11-PC	40-75	1.05	12	1.63	1.41	

Center for

UF FLORIDA

	12 Series MPR						180°	н	20 25	11 12	1.05 1.18	1.67 1.58	1.93 1.83	
									30	12	1.30	1.58 1.74	2.01	
	30°Trajectory								35	13	1.42	1.61	1.86	1
	Nozzle	Pressure psi	Radius ft.	Flow gpm	Precip In/h	Precip In/h			40	13	1.52	1.73	2.00	J
	12F	15	9	1.80	2.14	2.47								ļ
		20	10	2.10	2.02	2.34								
		25	11	2.40	1.91	2.21								ļ
_		30	12	2.60	1.74	2.01								
	12H	15	9	0.90	2.14	2.47								
1		20	10	1.05	2.02	2.34						60 V		100
111		25	11	1.20	1.91	2.21			1 1 1			/	- 1	
		30	12	1.30	1.74	2.01								
	ulan,			FU		AL V				μN			MA	

12 12' radius Fixed: ¼, ¼, ½, ⅔, ¾, Full • Green Trajectory: 28°

Arc	Position	Pressure PSI	Radius ft.	Flow GPM	Precip	o in∕hr ▲
		20	11	0.54	1.71	1.98
90	ŶQ	25	12	0.61	1.62	1.87
		30	12	0.67	1.78	2.06
	-	35	13	0.72	1.65	1.90
		40	13	0.78	1.77	2.04
		20	11	0.72	1.71	1.98
120	° T	25	12	0.81	1.62	1.87
		30	12	0.89	1.78	2.06
	•	35	13	0.97	1.65	1.90
		40	13	1.04	1.77	2.04
		20	11	1.05	1.67	1.93
180)°H	25	12	1.18	1.58	1.83
		30	12	1.30	1.74	2.01
		35	13	1.42	1.61	1.86
		40	13	1.52	1.73	2.00

EPA Estimated Savings


- Avg. house using 50,500 gal/yr saves 5,600 gal/yr
- 2.3 yr ROI retrofit

UF FLORIDA

IFAS

• 1.5 yr ROI new install

Center for




Irrigation System Pressure Data, Utah State University and Center for Resource Conservation

Misting and Drift




Pressure Regulation



No Pressure Regulation




How Do They Work?



EPA WaterSense Initial Testing

- Three labs
- Outlet device
 - Standardized orifice in 802
 - Ball valve/gate valve
 - Variable arc nozzle
 - Needle valve
- Increasing pressure/decreasing pressure
 → hysteresis

Initial Testing Observed Hysteresis



Outline


Man and Man Man Man Man Man Man

- Test equipment
- Test process
- Modifications
- Results


FLORIDA

Recommendations

Test Equipment



Water Hammer – Arrester




Booster Pump





Test Sample, pressure transducers, needle valve



Pressure Transducers

Adapter

Needle Valve

UF FLORIDA

Test Specimen

Test Process

- Verify flowrate at rated pressure (3 consecutive readings) 30 psi +/- 1 psi, 1.5 gpm +/- 0.1 gpm
- Reduce pressure to zero (for at least 1 min)
- Increase pressure to rated+10 psi (3-5 min test, 30 sec recording)

appli

- Reduce pressure to zero
- Increase pressure to 60 psi
- Reduce pressure to zero
- Increase pressure to 70 psi
- Repeat for 60 psi, rated+10 psi

Test Modifications

- All piping 1/2" SCH 40 PVC, not 3/4"
- First test point at regulated pressure to verify test conditions
- Accepted a 0.2 gpm deviation at 3.5 gpm test point




Models Tested


- 6 manufacturers
- 11 models tested, 3 samples each
- Brands A-C, PR and non-PR models tested
- One check valve model
- Two flow reduction models




Brand A Pressure Regulated vs. Non-Pressure Regulated – 1.5 gpm Test




Brand A Pressure Regulated vs. Non-Pressure Regulated – 3.5 gpm Test




Brand B Pressure Regulated vs. Non-Pressure Regulated – 1.5 gpm Test




Brand B Pressure Regulated vs. Non-Pressure Regulated – 3.5 gpm Test




Brand E PRB & Check Valve – 1.5 gpm Test




Brand E PRB & Check Valve – 3.5 gpm Test




PRB Replicate Tests– Brand A Sample #1 1.5 gpm



PRB Replicate Tests– Brand A Sample #1 3.5 gpm




Flowrate Reduction – PRB vs. Non-PRB @ 1.5 gpm




UF FLORIDA

Flowrate Reduction – PRB vs. Non-PRB @ 3.5 gpm




UF FLORIDA

Average Flowrate Reduction – PRB vs. Non-PRB




UF FLORIDA Center for LANDSCAPE

PRB Outlet Pressure




Average Pressure & Flowrate Error – 1.5 gpm




UF FLORIDA

Average Pressure & Flowrate Error <u>Rising</u> <u>Limb</u> – 1.5 gpm




UF FLORIDA IFAS

Average Pressure & Flowrate Error – 3.5 gpm





Average Pressure & Flowrate Error <u>Rising</u> <u>Limb</u> – 3.5 gpm




Recommendations

- Consider testing only the rising limb of pressure, e.g. for a 30 psi PRB, 40, 60, 70 psi test
- No compelling difference between 1.5 gpm & 3.5 gpm results
- Consider testing only 1.5 gpm since this flowrate is similar to the majority of sprinklers in the field
- Consider a maximum of 10-15% plus/minus deviation in peak flowrate at 1.5 gpm
- Consider average flowrate deviation maximum of 10-15% plus/minus at 1.5 gpm

h h h a h h h h a h h

Error Analysis on Individual Samples Criteria: 1.5 gpm actual flowrate rising limb



EPA Spec Criteria

- Flowrate at max operating pressure compared to calibration flowrate shall be within +/- 12.0%
- Average of all test flowrates compared to calibration flowrate shall be within +/-10.0%
- Average outlet pressure at initial calibration point shall not be less than 2/3 regulation pressure



Acknowledgements: EPA WaterSense Program

